



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No Nil dated 23.02.2024
Issued to :- The Headmistress
:- Northridge International School
:- Sector - 46 - A, Chandigarh
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 27-02-2024
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample Filled in P.P. and Glass Bottle
Source of sample :- from School tap of Northridge International School
Sector - 46 - A, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.78
2	Turbidity	< 1.0	mg/l	0.9
3	Residual Chlorine	0.2 - 0.4	mg/l	0.2
4	Total Alkalinity (as CaCO ₃)	< 200	mg/l	86
5	Total Hardness (as CaCO ₃)	< 200	mg/l	72
6	Chlorides (as Cl)	< 250	mg/l	04
7	Free & Saline Ammonia	Nil	mg/l	NIL
8	Total Dissolved Solids	< 500	mg/l	132
9	M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment: received vide receipt No.02/2023-24/180100, dated 26.02.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/ 800

Dated:- 29.02.2024



Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Endst No. MCPH/24/.....

Dated :-.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for Information Please.


Chemist
M.C.P.H. Laboratory


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1